



CITY OF BUCKEYE Fire Department

Construction Site Requirements

The following items shall be completed and maintained prior to delivery of any combustible materials to the site and maintained throughout construction:

- Fire Department and emergency vehicle access roadways shall be provided and maintained throughout construction.
- Temporary access roads shall be a minimum of 20 feet, clear width with 6 inches compacted AB, gravel or crushed granite forming an all-weather surface capable of supporting fire apparatus.
- No trenching across Fire Department and emergency vehicle access roads.
- Access roadways should extend so that the furthest point of the structure is within 150 feet.
- Access roadways that extend more than 150 feet from a hardened surface roadway (asphalt on concrete) will be provided with a hammerhead or turnaround. (Specifications can be obtained from the Fire Department)
- Fire Department and emergency vehicle access roadways shall be clearly marked with signs (red background/white letters) Fire Department Emergency Access.
- Parking and off-loading of materials on access roadways is prohibited.
- The water supply and hydrants shall be approved and functional.
- Fire hydrants shall be located within 8 feet of the roadway (temporary or permanent)
- In areas with developed and hardened roadways, construction parking will be restricted to one side only.

If you have any questions, feel free to contact Buckeye Fire Marshal Nate Ryan at 623-349-6759.

Date: _____

Signature: _____

Title: _____